



# PRODUCT PERFORMANCE RATING

Document ID 033120201102-11463482

Issued on 31 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	DAIKIN
Range	RXF
Product référence	RXF35A / FTXF35A

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
Lamptilamestarit Oy	Lamptilamestarit Oy	Lamptilamestarit Oy	Finland

FEATURE	VALUE	UNIT
<b>STANDARD COOLING/COOLING PL COND A</b>		
Pc	3.30	kW
Pec	1.00	kW
EER	3.30	



# PRODUCT PERFORMANCE RATING

Document ID 033120201102-11463482

Issued on 31 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>STANDARD HEATING</b>		
Ph	3.50	kW
Peh	0.94	kW
COP	3.71	

FEATURE	VALUE	UNIT
<b>ACOUSTIC</b>		
LwO env	62	dB(A)
LwI1 env	58	dB(A)

FEATURE	VALUE	UNIT
<b>COOLING PL CONDB</b>		
Pc @ 30°C	2.58	kW
EER @ 30°C	4.11	



# PRODUCT PERFORMANCE RATING

Document ID 033120201102-11463482

Issued on 31 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL CONDC</b>		
Pc @ 25°C	1.66	kW
EER @ 25°C	7.54	

FEATURE	VALUE	UNIT
<b>COOLING PL CONDD</b>		
Pc @ 20°C	1.36	kW
EER @ 20°C	12.46	

FEATURE	VALUE	UNIT
<b>SEASONAL EFFICIENCY IN COOLING</b>		
Pdesignc	3.50	kW
SEER	6.21	
Qce	197.00	kWh/annum
SEER Class	A++	



# PRODUCT PERFORMANCE RATING

Document ID 033120201102-11463482

Issued on 31 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL CONDA</b>		
Ph @ -7°C	2.48	kW
COP @ -7°C	2.78	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDB</b>		
Ph @ +2°C	1.51	kW
COP @ 2°C	4.01	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDC</b>		
Ph @ +7°C	0.97	kW
COP @ +7°C	5.10	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDD</b>		
Ph @ +12°C	1.13	kW
COP @ +12°C	6.54	



# PRODUCT PERFORMANCE RATING

Document ID 033120201102-11463482

Issued on 31 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING AVERAGE CLIMATE</b>		
Pdesignh	2.80	kW
SCOP	4.06	
SCOP Class	A+	
Qhe	965.00	kWh/annum

FEATURE	VALUE	UNIT
<b>BIVALENT POINT</b>		
Tbiv	-7	°C
COP @ Tbiv	2.78	
Ph TBiv	2.48	kW

FEATURE	VALUE	UNIT
<b>TOL RUNING TEST</b>		
TOL	-15.00	°C
COP @ TOL	2.06	
Ph @ TOL	2.09	kW



# PRODUCT PERFORMANCE RATING

Document ID 033120201102-11463482

Issued on 31 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>POFFC</b>		
Poff	1.00	W

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psb	1.00	W

FEATURE	VALUE	UNIT
<b>PTOC</b>		
Pto	12.00	W

FEATURE	VALUE	UNIT
<b>POFFH</b>		
Poffh	1.00	W

FEATURE	VALUE	UNIT
<b>PSBH</b>		
Psbh	1.00	W



# PRODUCT PERFORMANCE RATING

Document ID 033120201102-11463482

Issued on 31 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>PTOH</b>		
Ptoh	12.00	W

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
Edibatec Export	false	
Capacity Control	variable	
Main Power Supply	230-1-50	
Refrigerant	R32	
Refr. Line	5 m	m
Mounting	Wall mounted	