



# PRODUCT PERFORMANCE RATING

Document ID 032920201410-11463972

Issued on 29 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	mitsubishi heavy industries thermal systems
Range	ZS-W
Product référence	SRC35ZS-W/SRK35ZS-W

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
Lampotilamestarit Oy	Lampotilamestarit Oy	Lampotilamestarit Oy	Finland

FEATURE	VALUE	UNIT
<b>STANDARD COOLING/COOLING PL COND A</b>		
Pc	3.50	kW
Pec	0.89	kW
EER	3.93	



# PRODUCT PERFORMANCE RATING

Document ID 032920201410-11463972

Issued on 29 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>STANDARD HEATING</b>		
Ph	4.00	kW
Peh	0.94	kW
COP	4.26	

FEATURE	VALUE	UNIT
<b>ACOUSTIC</b>		
LwO env	61	dB(A)
LwI1 env	54	dB(A)

FEATURE	VALUE	UNIT
<b>COOLING PL CONDB</b>		
Pc @ 30°C	2.58	kW
EER @ 30°C	5.82	



# PRODUCT PERFORMANCE RATING

Document ID 032920201410-11463972

Issued on 29 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL CONDC</b>		
Pc @ 25°C	1.60	kW
EER @ 25°C	11.20	

FEATURE	VALUE	UNIT
<b>COOLING PL CONDD</b>		
Pc @ 20°C	1.07	kW
EER @ 20°C	18.50	

FEATURE	VALUE	UNIT
<b>SEASONAL EFFICIENCY IN COOLING</b>		
Pdesignc	3.50	kW
SEER	8.40	
Qce	146.00	kWh/annum
SEER Class	A++	



# PRODUCT PERFORMANCE RATING

Document ID 032920201410-11463972

Issued on 29 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL CONDA</b>		
Ph @ -7°C	2.65	kW
COP @ -7°C	2.50	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDB</b>		
Ph @ +2°C	1.62	kW
COP @ 2°C	4.92	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDC</b>		
Ph @ +7°C	1.04	kW
COP @ +7°C	6.10	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDD</b>		
Ph @ +12°C	1.16	kW
COP @ +12°C	7.86	



# PRODUCT PERFORMANCE RATING

Document ID 032920201410-11463972

Issued on 29 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING AVERAGE CLIMATE</b>		
Pdesignh	3.00	kW
SCOP	4.70	
SCOP Class	A++	
Qhe	895.00	kWh/annum

FEATURE	VALUE	UNIT
<b>BIVALENT POINT</b>		
Tbiv	-10	°C
COP @ Tbiv	2.40	
Ph TBiv	3.00	kW

FEATURE	VALUE	UNIT
<b>TOL RUNING TEST</b>		
TOL	-15.00	°C
COP @ TOL	2.10	
Ph @ TOL	2.52	kW



# PRODUCT PERFORMANCE RATING

Document ID 032920201410-11463972

Issued on 29 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>POFFC</b>		
Poff	4.00	W

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psb	4.00	W

FEATURE	VALUE	UNIT
<b>PTOC</b>		
Pto	10.00	W



# PRODUCT PERFORMANCE RATING

Document ID 032920201410-11463972

Issued on 29 March 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
Edibatec Export	true	
Capacity Control	Variable	
Main Power Supply	230-1-50	
Refrigerant	R32	
Refr. Line	5 m	m
Mounting	Wall mounted	