Information to identify the model(s) to which the information relates to:			If function includes heating: Indicate the heating season the			
Indoor unit model name SRK25ZTX-WA			information relates to. Indicated values should relate to one			
Outdoor unit model name	SRC25ZTX-WA	heating season at a time. Include at least the heating season 'Average'.				
Function(indicate if present)			Average(mandatory)	Yes		
cooling	Yes		Warmer(if designated)	No		
heating	Yes		Colder(if designated)	Yes		
Item	symbol value	unit	Item	symbol	value	class
Design load		kW	Seasonal efficiency and energy efficiency		0.50	
cooling heating / Average	Pdesignc <u>2.50</u> Pdesignh <u>3.00</u>		cooling heating / Average	SEER SCOP/A	9.50 5.20	A+++ A+++
heating / Warmer	Pdesignh -	kW	heating / Warmer	SCOP/W	-	-
heating / Colder	Pdesignh 4.40		heating / Colder	SCOP/C	4.10	A+
					unit	
Declared capacity at outdoor temperature		<u> </u>	Back up heating capacity at outdoor temp	-		7
heating / Average $(-10^{\circ}C)$	Pdc <u>3.00</u>		heating / Average (-10°C)	elbu	0	kW
heating / Warmer (2°C) heating / Colder (-22°C)	Pdc - Pdc 3.90	kW kW	heating / Warmer (2°C) heating / Colder (−22°C)	elbu elbu	0.5	kW kW
	1 40 0.00	K H		CIDU	0.0	
Declared capacity for cooling, at indoor te	mperature 27(19)°C and	Declared energy efficiency ratio, at indoor	temperature 27	(19)°C and		
outdoor temperature Tj			outdoor temperature Tj			-
Tj=35°C	Pdc 2.50		Tj=35°C	EERd	5.56	
Tj=30°C	Pdc 1.84		Tj=30°C	EERd	8.80	-
Tj=25°C Tj=20°C	Pdc 1.43 Pdc 1.49		Tj=25℃ Tj=20℃	EERd EERd	<u>12.60</u> 17.60	_
1j-20 C	Fuc 1.43	KW	[]_20 C	EERU	17.00	Γ
Declared capacity for heating / Average season, at indoor Declared coefficient of performance / Average season, at indoor						
temperature 20°C and outdoor temperatur	е Тј	temperature 20°C and outdoor temperature Tj				
Tj=−7°C	Pdh 2.65		Tj=-7°C	COPd	3.10	-
Tj=2°C	Pdh 1.62		Tj=2°C	COPd	5.40	
Tj=7°C	Pdh 1.04		Tj=7°C	COPd	6.50	-
Tj=12°C Tj=bivalent temperature	Pdh 1.16 Pdh 3.00		Tj=12°C Tj=bivalent temperature	COPd COPd	8.20 2.60	
Tj=operating limit	Pdh 3.00		Tj=operating limit	COPd	2.60	-
			······································		2.00	
Declared capacity for heating / Warmer season, at indoor			Declared coefficient of performance / Warmer season, at indoor			
temperature 20°C and outdoor temperatur			temperature 20°C and outdoor temperatur		r	7
Tj=2°C	Pdh -	kW	Tj=2°C	COPd	-	-
Tj=7°C Tj=12°C	Pdh <u>-</u> Pdh -	kW kW	Tj=7℃ Tj=12℃	COPd COPd	-	
Tj=bivalent temperature	Pdh - Pdh -	kW	Tj=12 C Tj=bivalent temperature	COPd	-	
Tj=operating limit	Pdh -	kW	Tj=operating limit	COPd	-	-
Declared capacity for heating / Colder sea			Declared coefficient of performance / Col		door	
temperature 20°C and outdoor temperatur			temperature 20°C and outdoor temperatur		0.40	Г
Tj=−7°C	Pdh 2.65		Tj=-7°C	COPd	3.10	-
Tj=2°C Tj=7°C	Pdh 1.62 Pdh 1.04		Tj=2°C Tj=7°C	COPd COPd	5.40 6.50	_
Tj=12°C	Pdh 1.16		Tj=12°C	COPd	8.20	1_
Tj=bivalent temperature	Pdh 3.59		Tj=bivalent temperature	COPd	2.35	1-
Tj=operating limit	Pdh 3.90	kW	Tj=operating limit	COPd	1.70]-
Tj=−15°C	Pdh 3.59	kW	Tj=-15°C	COPd	2.35	-
Bivalent temperature heating / Average	Tbiv -10	°C	Operating limit temperature heating / Average	Tol	-10	°C
heating / Warmer	Tbiv -IO		heating / Warmer	Tol	-10	č
heating / Colder	Tbiv -15	°Č	heating / Colder	Tol	-22	°Č
Cycling interval capacity	_		Cycling interval efficiency			-
for cooling	Pcycc -	kW	for cooling	EERcyc	-	-
for heating	Pcych -	kW	for heating	COPcyc	-	-
Degradation coefficient			Degradation coefficient			
cooling	Cdc 0.25	_	heating	Cdh	0.25	-
Electric power input in power modes other			Annual electricity consumption			
off mode	Poff 4	w	cooling	Qce	93	kWh/a
standby mode	Psb <u>4</u> Pto(cooling) 11	W W	heating / Average	Qhe	808	kWh∕a kWh∕a
thermostat-off mode	Pto(heating) 14	Ŵ	heating / Warmer heating / colder	Qhe Qhe	- 2252	kWn∕a kWh∕a
crankcase heater mode	Pck 0	Ŵ		Gante	LLUL	
			1			
Capacity control(indicate one of three opt	ions)		Other items			_
			Sound power level(indoor)	Lwa	54	dB(A)
- ·	N.		Sound power level(outdoor)	Lwa	55	dB(A)
ed No No		Global warming potential	GWP	675 702	kgCO2eq.	
staged variable	Yes		Rated air flow(indoor) Rated air flow(outdoor)	_	1860	m3/h m3/h
Contact details for obtaining		of the manufac	turer or of its authorised representative.			
	SERVICES B.V.					
	rbergweg 238, Luna Aren					
P.O.Bo	x 23393 1100 DW Amste	ruam, ivetnerlar	us			