



PRODUCT PERFORMANCE REPORT

Document ID 1528211357

Issued on June 5th, 2018

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Lämpötilamestarit Oy**
 Company **Lämpötilamestarit Oy**
 Project reference **Lämpötilamestarit Oy**
 Project location **Finland**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.077**
 Brand **PANASONIC**
 Range **2017**
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
 Product reference **CU-CZ9SKE / CS-CZ9SKE**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	61	dB(A)
Lw1 env	55	dB(A)
Bivalent Point		
Tbiv	-10	Å°C
COP @ Tbiv	2.32	
Ph TBiv	2.8	kW
General		
Mounting	W	
MPS	230-1-50	
Refrigerant	R32	
Refr. Line	5 m	m
Heating 14511		
Ph @+7	3.4	kW
COP @+7	4.66	
Heating Average Climate		
Pdesignh	2.8	kW
SCOP	4.1	
SCOP Class	A+	
Qhe	956.0	kWh/annum
Poffc		
Poff	7.0	W
Psbcc		



PRODUCT PERFORMANCE REPORT

Document ID 1528211357

Issued on June 5th, 2018

FEATURE	VALUE	UNIT
Psb	7.0	W
Ptoc		
Pto	28.0	W
Seasonal Efficiency in Cooling		
Pdesignc	2.5	kW
SEER	6.6	
SEER Class	A++	
Qce	133.0	kWh/annum
Thermal		
EER @+35	4.67	
TOL Runing Test		
TOL	-20.0	Â°C
COP @ TOL	1.87	
Ph @ TOL	1.97	kW